

EVAPORATOR CONTROL STATUS

ALARMS

Liquid
Line
Valve



Fan
Motor



Suction
Stop
Valve



Defrost
Relay
#1



Defrost
Relay
#2



Equal
Valve




System



Refr.
Leak



FUNCTION ACTIVE WHEN LIT



EVAPORATOR
CONTROL SYSTEM



EXIT

PRESS TO
SILENCE
ACTIVE
ALARM



SELECT
CHANGE

Press
to force
defrost

Defrost
manually
forced
when ill

